DCE.230 DC Energy Meter DCE.230 User Manual 1.7



1. Introduction

DCE.230 series DC energy meters are designed for measuring and monitoring in DC systems. The din rail DC energy meters can measure of important DC parameters: Voltage, current, power and energy etc. It also support bidirectional measurement with pulse output. All data in the meter are accessible via RS485 using Modbus RTU. The meter has DC power supply. Input voltage range up to 1000V DC, and current inputs are flexible with DC shunt and current sensors.

- Measures kWh, W, V, A etc.
- Bi-directional measurement IMP & EXP
- Pulse output RS485 Modbus
- . Din rail mounting 35mm
- DC shunt connection
- Class 1

1.1 General Specifications

Voltage DC Input: 100~1000V DC Auxiliary Supply: 9-40V DC DC Shunt Input: 75mV Current Range: 0~2000A Power consumption: $\leq 2W / 5VA$ AC voltage withstand: 4400V/ 1min Impulse voltage withstand: 6.4kV - 1.2/50µS waveform Pulse output: 1, 10, 100, 1000 imp/kWh (default) Pulse duration: 60, 100 (default), 200mS Pulse output indicate: Total kWh/ import kWh/ export kWh Display: LCD with backlit Max. Reading: 999999.9kWh Weight: 220g Standard: GB/T 33708-2017

1.2 Unit Characteristics

The Unit can measure and display:

voltage ٠

- Currents
- Power

Active energy imported and exported Pulse output indicates real-time energy measurement. An RS485 output allows remote monitoring from another display or a computer

1.3 Shunt Primary Current

The unit can be configured to operate with primary current and secondary input. Primary current range: 0~2000A. Second input: 75mV

1.4 RS485 Output for Modbus RTU

For Modbus RTU, the following RS485 communication parameters can be configured from the Set-up menu: Baud rate 1200,2400, 4800, 9600,19200

Parity none (default)/odd/even Stop bits 1 or 2

RS485 address 3-digit, 001 to 247

Modbus[™] Word order Hi/Lo byte order is set automatically to normal or reverse. It cannot be configured from the setup menu. Set-up screens are provided for setting up the RS485 port.

1.5 Pulse output

21-200

201-2000

The unit provides a pulse output. The constant can be configured to below: 10000 imp/kWh 1000 imp/kwh 100 imp/kWh 10 imp/kWh 1 imp/kWh Pulse width: 200/100(default)/60 ms Note: the relationship between pulse constant and CT1 CT1 Settable pulse imp/kW Default puls imp/kWl 1–20 1000 1000,100,10,1

Relative humidity 0 to 90%, non-condensing Altitude up to 2000m Installation category CATIII Mechanical Environment M1 Electromagnetic environment E2 Degree of pollution 2

1.8 Mechanics

Din rail dimensions 36x100x63 (WxHxD) DIN 43880 Mounting DIN rail 35mm Ingress Protection IP51 (indoor) Material Self-extinguishing UL94V-0

2. Operation

2.1 Initialization Display When it is powered on, the meter will initialize and do selfchecking.

∑Т8імРЕХРМD1л.л.2 888:888:888 PF Hz MkVarh MkWh 111 €© €⊐ ि	Full Screen (stay 2s)
02 0 10 1	Software Version (stay 2s) (This information is for reference only.)
888 OO I	Current Modbus address (stay 2s)
ъс <u>9</u> .5 *	Current baud rate (stay 2s)
z 00008.96 ^{kWh}	Total active energy(kWh) Total=Import+ Export Max read: 999999.9 kWh

2.1 Buttons function



2.1.1 Scroll display

After initialization and self-checking program, the meter displays the measured values. The default page is total kWh. If the user wants to check other information, please press the so

e scioli buttori oli the nont panel.			
s 00008.96 kWh	Total active energy(kWh) Total=Import+ Export Display format: 5+2 -> 6+1 -> 5+2 99999.99 -> 100000.0 -> 999999.9 -> 00000.00		
x / 00008.95 kWh	Partial resettable active energy Display format: 5+2 -> 6+1 -> 5+2 99999.99 -> 100000.0 -> 999999.9 -> 00000.00		
580.S	Voltage		

CE 1:1000	CT1 Primary current
Rdd 001	Meter address
64 19.2 *	Baud rate
ргуу П	Parity
02 0 10 1	Software Version

Set-up Mode

To get into Set-up Mode, the user need press the "Enter" button for 3 second.

PR5 <mark>0</mark> 000	1 Password To get into Set-up mode, it asks a password confirmation. Default password: 1000 Use Scroll and Set to enter correct password.
Rdd <mark>0</mark> 01	2 Keep pressing Set for 3 second, the current selection will flash, use Scroll and Set to change the Modbus address. Options: 1~247 Keep press Set for 3s to confirm the selection.
bd <mark>9.6</mark>	3 Keep pressing Set for 3 second, the current selection will flash, use Scroll and Set to change the Baud rate. Options: 1.2k, 2.4k,4.8k,9.6k (default),19.2k Keep press Set for 3s to confirm the selection.
РГЕ У <mark>П</mark>	4 Keep pressing Set for 3 second, the current selection will flash, use Scroll and Set to change the Parity. Options: EVEN, ODD, NONE (default)
PLS OUE	5 Keep pressing Set for 3 second, the current selection will flash, use Scroll and Set to change the type of Pulse Output. Options: total kWh, IMP kWh, EXP kWh
CSE 1000	6 Keep pressing Set for 3 second, the current selection will flash, use Scroll and Set to change the pulse constant. Options: 1000, 100, 10, 1 imp/kWh *Default pulse constant is related to the CT1 setting
51 A 100	7 Keep pressing Set for 3 second, the current selection will flash, use Scroll and Set to change the pulse width. Options: 60, 100, 200, unit: ms

	Default: 0 s, represent do not scroll display
<mark>₽ 60</mark> ⊙	11 Use Scroll to select the backlit time option. Keep pressing Set for 3 second, the current selection will flash, use Scroll and Set to enter the options:0,5,10, 20,30,60 minutes. 0 means the light is always on. Default: 60 min.
85 <mark>0</mark> 000	12 Use Scroll to select the Password option. Keep pressing Set for 3 second, the current selection will flash, use Scroll and Set to enter the new password. The range is from 0001 to 9999. Default: 1000
UUF <mark>U</mark>	13 Shunt wiring Use Scroll to select the shunt connection option. Keep pressing Set for 3 second, the current selection will flash, use Scroll to choose the connection way. Option: N, P N: Negative type (default) P: Positive type

Keep pressing SCROLL button to exit the set-up mold.

3. Wiring diagram

E

3.1 Terminal Connection DC Power Supply: 9-40 V DC Voltage DC Input: 5~1000V DC

voltage be in	put. 5 100	00000	
34	A+ B- G n+ n- 5 6 7 8 9 RS485 Pulse	AUX+ AUX- 13 14 Power Skippy	1 2

3.2 Shunt Connection DC Shunt Input: 75mV Current Range: 0~2000A



Below a listing of common shunt resistors

19	ESFL-2A Series			
Primary Input	Rated Voltage Output	Accuracy	Dimension(mm)	
10-50 A	75/60/45 mV	0.5%	25x120x22	
75-100 A	75/60/45 mV	0.5%	23x109x11	
150-200 A	75/60/45 mV	0.5%	22x118x22	
300 A	75/60/45 mV	0.5%	26x127x22	
400 A	75/60/45 mV	0.5%	36x127x22	
500 A	75/60/45 mV	0.5%	46x127x22	
500 A	75/60/45 mV	0.5%	55x127x22	
750 A	75/60/45 mV	0.5%	76x127x22	
1000 A	75/60/45 mV	0.5%	96x127x22	
1500 A	75/60/45 mV	0.5%	113x127x22 or 87x200x97	
2000 A	75/60/45 mV	0.5%	136x200x97	

5. Dimensions



*when the CT setting on meter is 2000A, the default pulse constant is 10 imp/kWh and it can be set to 10imp/kWh or 1 imp/kWh.

100,10,1

10,1

100

10

*Over-current alarm: Alarm will happened when the current is over the CT1 value set on the meter. The Alarm LED will stay solid and the corres-ponding register value will be changed. The user can read this register through communication to determine whether an overcurrent alarm has occurred.

The pulse outputs can be set to generate pulses to represent Import kWh/ Export kWh/ total kWh.

The pulse output is passive type, complies with IEC62053-31 Class A



ATTENTION: Pulse output must be fed as shown in the wiring diagram below. Scrupulously respect polarities and the connection mode. Opto-coupler with potential-free SPST-NO Contact. Contact range:5-27VDC Max. current Input:27mA DC.

1.7 Environment
Operating temperature -25 to + 55°C

Reference temperature 23 °C±2°C

ז ר <u>8</u> ר ^	Current	
38.468 ***	Power Display format: <1000 W: XXX W <1000kW: XXX.XXX kW For other value: XXXX.XX kW	
C 1000	Pulse constant	







Qonnex bv B-9310 Aalst Belgium Email: info@2-wire.be www.2-wire.be